

Bedienungsanleitung (Originalanleitung)
Druckmessumformer Serie HDA 4000
für das Medium Wasserstoff mit HART Schnittstelle
für eigensichere Stromkreise und Schutz durch Gehäuse mit
ATEX und IECEx-Zulassung

Operating Instructions (Translation of original instructions)
Pressure Transmitter Series HDA 4000
for hydrogen applications with HART interface
for intrinsically safe circuits and protection by enclosure
with ATEX and IECEx approval



Schutzklassen und Einsatzbereiche / Protection types and zones:

ATEX		
13ATEX0031X	I M1	Ex ia I Ma
	II 1G	Ex ia IIC T6,T5 Ga
	II 1/2 G	Ex ia IIC T6,T5 Ga/Gb
	II 2 G	EX ia IIC T6,T5 Gb
	II 1D	Ex ia IIIC T85 °C or T95 °C Da
	II 1D	Ex ta IIIC T80/90/100 °C T ₅₀₀ T90/T100/T110 °C Da
13ATEX0032	II 2D	Ex tb IIIC T80/90/100 °C Db
	II 3G	Ex nA IIC T6, T5, T4 Gc
	II 3G	Ex ic IIC T6, T5, T4 Gc
	II 3D	Ex tc IIIC T80/T90/T100 °C Dc
	II 3D	Ex ic IIIC T80/T90/T100 °C Dc
IECEx		
IECEx DEK 14.0011X	Ex ia I Ma	
	Ex ia IIC T6,T5 Ga	
	Ex ia IIC T6,T5 Ga/Gb	
	Ex ia IIC T6,T5 Gb	
	Ex ia IIIC T85 °C or T95 °C Da	
	Ex ta IIIC T80/90/100 °C Da T ₅₀₀ 90/100/110 °C Da	
	Ex tb IIIC T80/90/100 °C Db	
	Ex nA IIC T6/ T5 T4 Gc	
	Ex ic IIC T6/ T5/T4 Gc	
	Ex tc IIIC T80/90/100 °C Dc	
	Ex ic IIIC T80/90/100 °C Dc	

ATEX certificate: DEKRA 13ATEX0031 X
DEKRA 13ATEX0032

Testing laboratory: DEKRA, Test Report No.NL/DEK/ExTR13.0001/xx

IECEx certificate: IECEx DEK 14.0011X

Testing laboratory: DEKRA, Test Report NL/DEK/ExTR13.0001/01

Inhaltsverzeichnis / Table of Contents

Deutsch

1	Allgemeines.....	4
2	Funktion.....	4
3	Montage und Inbetriebnahme.....	4
4	Wichtige Hinweise für die Conduit-Installation	5
4.1	Installationshinweise für Geräte mit 1/2 " NPT Conduit.....	5
4.2	Installationshinweise für Geräte mit Schlagschutz	6
5	Allgemeine Sicherheitshinweise	7
6	Technische Daten	8
6.1	HDA 4000 Standard	8
6.2	HDA 4000 mit Option Temperaturmessung	9
6.3	Messbereichsgrenzen:.....	10
6.4	Protokolldaten	10
7	Typenschlüssel zur Identifikation des gelieferten Gerätes	11
7.1	Standard HDA 4000	11
7.2	Typenschlüssel HDA 4400 / HDA 4700 mit Option Temperaturmessung	11
8	Seriennummer.....	12
9	Anschlussbelegung.....	12
10	Abmessungen	13
10.1	Mechanische Anschlussvarianten.....	14
10.2	Elektrische Anschlussvarianten	14

Anhang

11	Kontrollzeichnung	29
11.1	Kontrollzeichnung Ex ia, Ex ic	29
11.2	Kontrollzeichnung Ex nA, Ex ta, tb, tc	30
12	Zertifikate	31
12.1	ATEX	31
12.2	IECEx.....	37
13	Konformitätserklärungen.....	42

English

1	General	17
2	Function.....	17
3	Installation and Commissioning Information.....	17
4	Important Mounting Instructions for Conduit Connection	18
4.1	Installation Instructions for Units with 1/2 " NPT Conduit	18
4.2	Installation Instructions for units with impact protection	19
5	General safety precautions.....	20
6	Technical Data	21
6.1	HDA 4000 Standard.....	21
6.2	HDA 4000 with the option of temperature measurement	22
6.3	Measuring Range Limits:	23
6.4	Protocol data.....	23
7	Model code to identify the delivered part.....	24
7.1	Standard HDA 4000.....	24
7.2	Model code HDA 4400 / HDA 4700 with additional option of temperature measurement	24
8	Serial number	25
9	PIN connection.....	25
10	Dimensions	26
10.1	Mechanical Connection Variants.....	27
10.2	Electrical Connection Variants	27

Appendix

11	Control Drawing	29
11.1	Control Drawing Ex ia, Ex ic	29
11.2	Control Drawing Ex nA, Ex ta, tb, tc.....	30
12	Certificates	31
12.1	ATEX	31
12.2	IECEx.....	37
13	Declaration of conformity	42

1 Allgemeines

Falls Sie Fragen bezüglich der technischen Daten oder Eignung für Ihre Anwendungen haben, wenden Sie sich bitte an unseren **technischen Vertrieb**. Die Druckmessumformer HDA 4000 werden einzeln auf einem rechnergesteuerten Prüfplatz abgeglichen und einem Endtest unterzogen. Sie sind wartungsfrei und sollten beim Einsatz innerhalb der Spezifikationen (siehe Technische Daten) einwandfrei arbeiten. Falls trotzdem Fehler auftreten, wenden Sie sich bitte an den **HYDAC-Service**. Nicht vorschriftgemäße Montage oder Fremdeingriffe in das Gerät führen zum Erlöschen jeglicher Gewährleistungsansprüche sowie der ATEX und IECEx Zulassung.

2 Funktion

Das vom Sensor gemessene Drucksignal wird in ein, dem Druck proportionales, analoges 4..20 mA Signal umgewandelt. Neben der analogen Ausgabe des Messwertes ist eine digitale Kommunikation mit Hilfe des HART Protokolls möglich.

3 Montage und Inbetriebnahme

Die Druckmessumformer können auf Prozess-Seite direkt über den Gewindeanschluss montiert werden.

Um in kritischen Anwendungsfällen (z.B. starke Vibrationen oder Schläge) einer mechanischen Zerstörung vorzubeugen, empfehlen wir das Gerät mittels einer Schelle mit Elastomereinsatz zu befestigen, sowie den Hydraulikanschluss über eine Minimes-Leitung zu entkoppeln.

Anzugsdrehmoment siehe Abmessungen.

Bei Druckmessumformern mit der Option Temperaturmessung ist der Temperaturfühler im Zapfen vor dem Gewinde integriert. Um eine korrekte Messung durchzuführen muss sichergestellt werden, dass der Zapfen sich im Strömungsmedium befindet.

Druckmessumformer mit einem Nenndruck ≤ 100 bar (≤ 1500 psi) besitzen einen Druckausgleich zum Umgebungsdruck. Hierzu befindet sich unter der Steckerbefestigung eine kleine Bohrung. Diese ist von innen mit einer speziellen Membrane abgedeckt, die verhindert, dass Feuchtigkeit von außen in das Gerät eindringen kann. Um eine Verstopfung der Bohrung zu verhindern, sollte bei feuchter und staubhaltiger Umgebung die Montage daher waagrecht oder senkrecht mit dem Druckanschluss nach unten erfolgen. Bei einem fest angeschlossenen Mantelkabel kann der Druckausgleich als kundenspezifische Modifikation auch über einen, im Kabel integrierten, Entlüftungsschlauch ausgeführt sein. Bei der Zündschutzart nA, ta und tb ist sicherzustellen, dass diese Entlüftung in den Nicht-Ex-Bereich erfolgt.

Bei Druckmessumformern mit einem Nenndruck von ≤ 100 bar (≤ 1500 psi) und einem elektrischen Anschluss mittels $\frac{1}{2}$ -14 NPT oder M20x1,5 Conduit ist der Druckausgleich bei Einzeladern entweder mittels einer kurzen Entlüftungslitze oder durch eine Bohrung realisiert, welche sich am elektrischen Anschluss befindet.

Die Installation muss von einem Fachmann nach den jeweiligen Landesvorschriften zu potentiell explosionsgefährdeten Umgebungen durchgeführt werden (z.B. IEC / EN 60079-14). Die Druckmessumformer der Serie HDA 4000 tragen das **CE**-Zeichen. Die Konformitätserklärung befindet sich im Anhang.

Die Forderungen der Normen (siehe techn. Daten) werden nur bei ordnungsgemäßer und fachmännischer Erdung des Druckmessumformergehäuses mittels des Prozessanschlusses oder dem $\frac{1}{2}$ NPT Conduit erreicht. Sofern eine grün/gelbe Ader vorhanden ist, darf diese zusätzlich, aber nicht zur alleinigen Erdung verwendet werden. Bei Schlauchmontage des Druckmessumformers muss das Gehäuse separat geerdet werden.

Die zugehörigen eigensicheren Geräte (z.B. Zenerbarrieren) sind ebenfalls zu erden. Ein Potentialausgleich entlang des eigensicheren Stromkreises ist in der Ausführungsvariante N (Isolationsspannung ≤ 50 VAC) erforderlich.

Bei der Serie HDA 4000 in der Ausführungsform H (Isolationsspannung ≤ 500 VAC) darf die Kabellänge zum Druckmessumformer maximal 30m betragen (Überspannungsschutz nach DIN EN 61000-6-2). Wenn die Kabellänge 30 m überschreitet, muss der Überspannungsschutz kundenseitig sichergestellt werden.


Allgemeine Sicherheitshinweise (vgl. Kapitel 5) sind in jedem Fall zu beachten.

4 Wichtige Hinweise für die Conduit-Installation

4.1 Installationshinweise für Geräte mit 1/2 " NPT Conduit


Mechanische Installation

Für die Montage des Prozessanschlusses darf nur die Schlüssel­fläche an der Prozessanschlus­seite des Druckmessumformers verwendet werden.



Elektrische Installation

Die Schlüssel­fläche an der Seite des elektrischen Anschlusses dient nur zum Fixieren des Druckmessumformers bei der Conduit-Installation.



4.2 Installationshinweise für Geräte mit Schlagschutz

Installationshinweise für Geräte mit M12x1 Stecker mit Schlagschutz-/Sicherungs- Metallhülse für den Einsatz in:

ATEX

II 3G Ex nA IIC T6,T5 Gc

II 1D Ex ta IIIC T80/T90 °C T₅₀₀90/ T₅₀₀100 °C Da

II 2D Ex tb III C T80/T90 °C Db

IECEx

Ex nA IIC T6,T5 Gc

Ex ta IIIC T80/T90 °C T₅₀₀90/ T₅₀₀100 °C Da


Ex tb III C T80/T90 °C Db

Zur Einhaltung der Sicherheitsrichtlinien in diesen Schutzklassen und Einsatzbereichen ist die Verwendung der Schlagschutz-/ Sicherungs- Metallhülse zwingend erforderlich.

Die Schlagschutz-/Sicherungs- Metallhülse ist mit einem Anzugsdrehmoment von 20 Nm anzuziehen.

Die Schlüsselfläche 27mm an der Seite des elektrischen Anschlusses dient nur zum Fixieren des Druckmessumformers bei Installation der Schlagschutz-/Sicherungs-Metallhülse.

Das Anschlusskabel mit M12x1 Stecker muss im spannungslosen Zustand ordnungsgemäß angeschlossen und die mitgelieferte Schlagschutz-/Sicherungs-Metallhülse montiert werden. Auch die Trennung des M12x1 Steckers darf nur im Spannungslosen Zustand erfolgen.





5 Allgemeine Sicherheitshinweise

Wenn das Etikett nicht mehr lesbar ist, muss der Druckmessumformer außer Betrieb gesetzt werden.

Die Druckmessumformer mit der Zündschutzart Eigensicherheit sind generell mit einer geeigneten, eigensicheren Barriere zu betreiben.

Die Dichtungen sind in regelmäßigen Abständen, in Abhängigkeit der klimatischen Bedingungen und dem Medieneinfluss, auf ihre Funktionstüchtigkeit zu kontrollieren, und wenn erforderlich auszutauschen. Ersatzdichtungen und –flachdichtungen können von der HYDAC ELECTRONIC GMBH bezogen werden. (Standarddichtungen siehe Technische Daten) Diese Überprüfung muss mindestens alle drei Jahre durchgeführt werden.

Bei gleichzeitigem Einsatz in Zone 0 und 1 wirkt die Metall-Messmembrane des Druckmessumformers als "Trennwand" zwischen Zone 0 und Zone 1. Die Dicke dieser "Trennwand" ist generell ≤ 1 mm und bei Nenndruck unter 100 bar $\leq 0,2$ mm. Zur Sicherstellung dieser Trennfunktion ist unbedingt auf die Verträglichkeit der Messmedien mit den verwendeten Werkstoffen und Dichtungen des Druckmessumformers zu achten, ebenso sind die Überlast- und Berstdrücke unbedingt einzuhalten (Angaben hierzu siehe "Technische Daten").

Die im Zertifikat angegebenen "Sicherheitstechnische Daten" sind einzuhalten.

Die interne Messmembrane des Druckmessumformers ist unbedingt vor mechanischer Beschädigung zu schützen.

Ebenso ist auf eine ausreichende Dichtung zwischen den Zonen zu achten.

Die Daten hinsichtlich der Nutzung in explosionsgefährdeten Umgebungen sind in jedem Fall zu berücksichtigen.

Der Betrieb ist nur zulässig, wenn anwendungs- und prozessbedingte intensive elektrostatische Aufladungsprozesse ausgeschlossen sind.

Bei Einsatz in Atmosphären von brennbaren Stäuben ist der Druckmessumformer geschützt vor Beschädigungen und Schlag anzubringen.

Zur Einhaltung der Sicherheitsrichtlinien ist für die Schutzklassen und Einsatzbereiche:

ATEX: II 3G Ex nA IIC T6,T5 Gc

IECEx: Ex nA IIC T6,T5 Gc

die Verwendung der Schlagschutz-/ Sicherungs- Metallhülse zwingend erforderlich. Die Schlagschutz-/Sicherungs- Metallhülse ist mit einem Anzugsdrehmoment von 20 Nm anzuziehen.

Der Betrieb in Bereichen die Kategorie 1G Betriebsmittel erfordern, ist nur zulässig, wenn anwendungs- und prozessbedingte intensive elektrostatische Aufladungsprozesse ausgeschlossen sind.

6 Technische Daten

6.1 HDA 4000 Standard

Eingangskenngrößen													
Messbereiche	bar	16	25	40	60	100	200	250	400	500	600	1050	
Überlastbereiche	bar	50	50	80	120	200	500	500	800	1000	1000	1400	
Berstdruck	bar	125	125	200	300	500	1250	1250	2000	3000	3000	3000	
Messbereiche	psi	300	500	750	1500	3000	5000	6000	9000	15000			
Überlastbereiche	psi	725	1160	1740	2900	7250	11600	14500	14500	20300			
Berstdruck	psi	1800	2900	4350	7250	18000	29000	43500	43500	43500			
Mechanischer Anschluss (Anzugsdrehmoment, empfohlen)	SF250CX20, Autoclave (7/16-20 UNF 2B) (15 Nm für Messbereich ≤ 600 bar/9000 psi) (20 Nm für Messbereich 1050 bar/15000 psi) G 1/4 B DIN EN 837 (20 Nm für Messbereich ≤ 600 bar/ 9000 psi) (40 Nm für Messbereich 1050 bar/15000 psi)												
Medienberührende Teile	Edelstahl	1.4435; (Ni Gehalt ≥13%)											
	Messzelle	goldbeschichtet											
	Dichtung	Kupfer (Cu-DHP) (G 1/4 B) Zurcon ® Z22 (SAE 8)											
Ausgangsgrößen		HDA 4400						HDA 4700					
Ausgangssignal, zulässige Bürde		4...20 mA, 2-Leiter, mit HART Protokoll R _{Lmax.} =(UB - 12 V) / 20 mA [kΩ] für HART Kommunikation min. 250 Ω											
HART Kommunikation		gemäß HART 7 Spezifikation											
HART Common Practice Commands z. B.		Ändern der Messbereichsgrenzen (siehe Tabelle), Nullpunktabgleich im Bereich max. 3 % der Spanne											
Genauigkeit nach DIN 16086, Grenzpunkteinstellung	Typ.	≤ ± 0,5 % FS						≤ ± 0,25 % FS					
	Max.	≤ ± 1,0 % FS						≤ ± 0,5 % FS					
Genauigkeit bei Kleinstwerteinstellung (B.F.S.L)	Typ.	≤ ± 0,25 % FS						≤ ± 0,15 % FS					
	Max.	≤ ± 0,5 % FS						≤ ± 0,25 % FS					
Temperaturkompensation Nullpunkt	Typ.	≤ ± 0,015 % FS/°C [0,0085 % FS/°F]						≤ ± 0,008 % FS/°C [0,0045 % FS/°F]					
	Max.	≤ ± 0,025 % FS/°C [0,014 % FS/°F]						≤ ± 0,015 % FS/°C [0,0085 % FS/°F]					
Temperaturkompensation Spanne	Typ.	≤ ± 0,015 % FS/°C [0,0085 % FS/°F]						≤ ± 0,008 % FS/°C [0,0045 % FS/°F]					
	Max.	≤ ± 0,025 % FS/°C [0,014 % FS/°F]						≤ ± 0,015 % FS/°C [0,0085 % FS/°F]					
Nicht-Linearität bei Grenzpunkt- einstellung nach DIN 16086		Max. ≤ ± 0,3% FS						≤ ± 0,3% FS					
Hysterese		Max. ≤ ± 0,4 % FS						≤ ± 0,1 % FS					
Wiederholbarkeit		≤ ± 0,1 % FS						≤ ± 0,1 % FS					
Anstiegszeit		≤ 25 ms						≤ 25 ms					
Langzeitdrift		Typ. ≤ ± 0,3 % FS / Jahr						≤ ± 0,3 % FS / Jahr					
Umgebungsbedingungen													
Kompensierter Temperaturbereich		-25 .. +85 °C [-13 .. +185 °F] gelb für englisch erweitern											
Betriebs-/ Umgebungs- Mediumstemperaturbereich		T6, T80/T85 °C : Ta = -40 .. +60 °C [-40 .. +140 °F] T5, T90/T95 °C : Ta = -40 .. +70 °C [-40 .. +158 °F] T100 °C : Ta = -40 .. +80 °C [-40 .. +176 °F] T4 : -40 .. +85 °C [-40 .. +185 °F]											
Lagertemperaturbereich		-40 .. +100 °C											
CE - Zeichen		EN 61000-6-1/ 2/ 3/ 4 ; EN 60079-0/ 11/ 15/ 26; EN 50303											
Vibrationsbeständigkeit nach DIN EN 60068-2-6 bei 10 ..500Hz		≤ 20 g ≤ 10 g bei Geräten mit elektr. Anschluss ½ NPT Conduit											
Schockfestigkeit nach DIN EN 60068-2-27		≤ 100 g / 6 ms											
Schutzart nach ¹⁾ DIN EN 60529 ISO 20653		IP 67 (Stecker EN175301-803 und Stecker M12x1) IP6K9K (½-14 NPT Conduit)											

Relevante Daten für die Ex-Anwendung		Ex ia, ic	Ex nA
Versorgungsspannung		U _i = 12 .. 28 V	12 .. 28 V
Maximaler Speisestrom		I _i = 100 mA	
Maximale Speiseleistung		P _i = 0,7 W	Max. Leistungsaufnahme ≤ 1W
Anschlusskapazität des Sensors		C _i = ≤ 22 nF	
Induktivität des Sensors		L _i = 0 mH	
Isolationsspannung ²⁾		50 V AC, mit integriertem Überspannungsschutz nach EN 61000-6-2 oder 500 VAC	
Sonstige Größen			
Restwelligkeit		Gemäß FSK Physical Layer Specification (HCF_SPEC-054)	
Versorgungsspannung			
Stromaufnahme		≤ 25 mA	
Lebensdauer		> 10 Mio. Lastwechsel 0 .. 100 % FS	
Gewicht		ca. 150 g (Gerätestecker) ca. 300 g (Conduit)	

Anmerkung: **FS (Full Scale)** = bezogen auf den vollen Messbereich

B.F.S.L. = Best Fit Straight Line

Verpolungsschutz der Versorgungsspannung, Überspannung-, Übersteuerungsschutz
Lastkurzschlussfestigkeit sind vorhanden.

¹⁾ Bei montierter Kupplungsdose entsprechender Schutzart

²⁾ Siehe Typenschlüssel „Isolationsspannung“

6.2 HDA 4000 mit Option Temperaturmessung

Zusätzliche technische Daten mit Option Temperaturmessung:

Eingangsgrößen									
Messbereich		Standard: -25 .. +100 °C [-13 .. +212 °F] Modifikation H01: -40 .. +100 °C [-40 .. +212 °F]							
Fühlerlänge		7 mm							
Anschlussart mechanisch		G 1/2 A ISO 1179-2 mit Messzapfen							
Anzugsdrehmoment, empfohlen		45 Nm							
Messbereich Druck	bar	16	40	60	100	250	400	500	
	psi	300	500	1000	3000	5000	6000		
Ausgangsdaten		HDA 4400				HDA 4700			
Ausgangssignal Temperatur		Das Temperatursignal ist als Sekundärvariable über HART-Protokoll als digitales Signal verfügbar							
Genauigkeit bei Raumtemperatur	Typ.	≤ ± 1,0 % FS				≤ ± 0,4 % FS			
	Max.	≤ ± 2,0 % FS				≤ ± 0,8 % FS			
Temperaturdrift (Umgebung)		≤ ± 0,02 % FS/ °C [0,01 % FS/ °F]				≤ ± 0,01 % FS/ °C [0,005 % FS/ °F]			
Anstiegszeit nach DIN EN 60751		t ₅₀ : ~ 10 s							
		t ₉₀ : ~ 15 s							

6.3 Messbereichsgrenzen:

Mittels HART Common Practice Commands haben Sie die Möglichkeit folgende Messbereichsgrenzen einzustellen:

Messbereichsgrenzen der Primärvariablen (PV) Druck für die Standardgeräte mit Modifikation H00):

Untere Messbereichsgrenze		Obere Messbereichsgrenze		Messspanne	
min	max	min	max	min	max
0 % FS	112,5 % FS	37,5 % FS	150 % FS	37,5 % FS	150 % FS

Messbereichsgrenzen der Primärvariablen (PV), Druck für das Gerät mit 500 bar Messbereich und Modifikation H01:

Untere Messbereichsgrenze		Obere Messbereichsgrenze		Messspanne	
min	max	min	max	min	max
0 % FS	62,5 % FS	37,5 % FS	100 % FS	37,5 % FS	100 % FS

Für Geräte mit Option Temperaturmessung HDA 4000-T

Messbereichsgrenzen der Sekundärvariablen (SV) Temperatur für die Standardgeräte mit Messbereich Temperatur -25 .. +100°C:

Untere Messbereichsgrenze		Obere Messbereichsgrenze		Messspanne	
min	max	min	max	min	max
-25 °C	75 °C	0 °C	100 °C	25 °C	125 °C

Messbereichsgrenzen der Sekundärvariablen (SV) Temperatur für das Gerät mit Modifikation H01 mit Messbereich Temperatur -40 .. +100 °C:

Untere Messbereichsgrenze		Obere Messbereichsgrenze		Messspanne	
min	max	min	max	min	max
-40 °C	112 °C	28 °C	140 °C	28 °C	140 °C

6.4 Protokolldaten

HART Version: 7
 Manufacturer Code: 0x605E
 Manufacturer String: HYDAC ELECTRONIC
 Device Type Code: 0xE1BC Variante mit Druck als PV
 0xE2A7 Variante mit Druck als PV und Temperatur als SV

7 Typenschlüssel zur Identifikation des gelieferten Gerätes

7.1 Standard HDA 4000

HDA 4 X X X - F21 - XXXXX - E X X - HXX (XXX)

Genauigkeit

4 = 1 % FS max.
7 = 0,5 % FS max.

Anschlussart mechanisch

C = SF250CX20, Autoclave (7/16-20 UNF 2B), Innengewinde
G = G1/4 B DIN EN 837

Anschlussart elektrisch

5 = Gerätestecker, EN 175301-803, 3 pol. + PE
6 = Gerätestecker, M 12 x 1, 4 pol.
9 = 1/2-14 NPT Conduit, Einzeladern

Ausgangssignal

F21 = 4 .. 20 mA, 2-Leiter, mit HART Protokoll

Messbereiche

4 stellig für bar-Version
5 stellig für psi-version

Zulassung

E = ATEX + IECEx (genauere Angaben siehe Zertifikate)

Isolationsspannung

H = 500 V AC gegen Gehäuse
N = 50 V AC gegen Gehäuse

Schutzklassen und Einsatzgebiete

ATEX	IECEx
1 = I M1 Ex ia I Ma	Ex ia I Ma
II 1G Ex ia IIC T6,T5 Ga	Ex ia IIC T6,T5 Ga
II 1/2 G Ex ia IIC T6,T5 Ga/Gb	Ex ia IIC T6,T5 Ga/Gb
II 2 G Ex ia IIC T6,T5 Gb	Ex ia IIC T6,T5 Gb
II 1D Ex ia IIC T85/T95 °C Da	Ex ia IIC T85/T95 °C Da
9 = II 3G Ex nA IIC T6, T5 Gc	Ex nA IIC T6, T5 Gc
nur in Verbindung mit elektrischem Anschluss „6“ und der Schlagschutz-Sicherungs-Metallhülse, siehe auch Kapitel 4.2	
C= II 3G Ex ic IIC T6, T5 Gc	Ex ic IIC T6, T5 Gc
II 3D Ex ic IIC T80/T90 °C Dc	Ex ic IIC T80/T90 °C Dc

Modifikationsnummer

H00 = Standard

Bei Geräten mit anderer Modifikationsnummer ist das Typenschild bzw. die mitgelieferte technische Änderungsbeschreibung zu beachten.

Kabellänge (für Conduit Versionen, entfällt bei Gerätesteckern)

Angabe in m oder "(inch)

7.2 Typenschlüssel HDA 4400 / HDA 4700 mit Option Temperaturmessung

HDA 4 X 2 X - F21 - XXXXX - T - 007 - XXX - HXX

Anschlussart, mechanisch

2 = G 1/2 A ISO 1179-2

Optional mit Temperaturmessung

Über HART Protokoll als digitales Signal

Fühlerlänge

007 = 7mm [0,276 inch]

Modifikationsnummer

H00 = Standard
H01 = Messbereich Temperatur -40 .. +100°C


8 Seriennummer

Die Seriennummer enthält die Kalenderwoche und das Jahr, in dem das Gerät hergestellt wurde, neben der sequentiellen Seriennummer.

xyyykzzzzzz

Aufbau der Seriennummer:


X	Fertigungsjahr	z. B. : 6 → 2016
yy	Kalenderwoche	z. B.: 24 → KW24
k	Seriennummer-Index	z. B. : -,A,B
zzzzzz	fortlaufende Seriennummer	z. B.: 123456



9 Anschlussbelegung


Die Anschlussbelegung für den elektrischen Anschluss ist sowohl im Kapitel "Kontrollzeichnung", als auch auf dem Typenschild des Druckmessumformers dargestellt.

10 Abmessungen




10.1 Mechanische Anschlussvarianten

SF 250CX20, Autoclave, (7/16-20 UNF 2B), Innengewinde




Mechanischer Anschluss G 1/2 A ISO 1179-2 mit Option Temperaturmessung



10.2 Elektrische Anschlussvarianten

Gerätestecker EN175301-803 3-pol.+PE



This image shows a full page of blank graph paper. The grid consists of small, equal-sized squares formed by thin black lines. There are no margins, text, or other markings on the page.

HYDAC ELECTRONIC GMBH
Hauptstraße 27
D - 66 128 Saarbrücken
Deutschland

Web: www.hydac.com
E-Mail: electronic@hydac.com
Tel.: +49-(0)6897-509-01
Fax.: +49 (0)6897 509-1726

HYDAC Service

Für Fragen zu Reparaturen steht Ihnen der HYDAC Service zur Verfügung:

HYDAC SERVICE GMBH
Hauptstr. 27
D - 66 128 Saarbrücken
Deutschland

Tel.: +49-(0)6897-509-1936
Fax.: +49 (0)6897 509-1933

Anmerkung

Die Angaben in diesem Handbuch beziehen sich auf die beschriebenen Betriebsbedingungen und Einsatzfälle. Bei abweichenden Einsatzfällen und/oder Betriebsbedingungen wenden Sie sich bitte an die entsprechende Fachabteilung.

Bei technischen Fragen, Hinweisen oder Störungen nehmen Sie bitte Kontakt mit Ihrer HYDAC-Vertretung auf.

Technische Änderungen sind vorbehalten.

1 General

If you have any queries regarding technical details or the suitability of the unit for your application, please contact our **Technical Sales Department**. The series HDA 4000 pressure transmitters are individually tested and calibrated at a computer operated test station. They are maintenance-free and operate perfectly when used according to the data (see Technical Data). However, if there is a cause for complaint, please contact **HYDAC Service**. Incorrect use or interference by anyone other than HYDAC personnel will cause all warranty claims and ATEX and IECEx approvals to become null and void.

2 Function

The pressure signal measured by the sensor is converted into a proportional analogue 4..20 mA signal. In addition with the analogue output of the measured value, digital communication is possible by means of the HART protocol.

3 Installation and Commissioning Information

The pressure transmitters can be installed directly on the process side via the threaded connection.

In order to prevent mechanical damage when dealing with critical applications involving heavy vibrations or blows, for example, we recommend securing the unit with an elastomer clamp and decoupling the hydraulic ports via a Minimesh hose.

Tightening torque see dimensions.

In pressure transmitters with additional temperature measurement the temperature probe is integrated into the stem in front of the thread. To perform correct measurements, it must be ensured that the stem is placed in the flow of the medium.

Pressure transmitters with a rated pressure of < 100 bar (≤ 1500 psi) provide for pressure equalisation with the ambient pressure. This is enabled by a small hole underneath the plug connector. The connector is covered by a special membrane from the inside which prevents moisture from seeping into the unit from the outside. In order to prevent the hole from becoming clogged, mounting should be done in a horizontal position in moist or dusty environments, or vertically with the pressure port pointing downwards. In the case of a firmly connected jacket cable, the pressure compensation can also be designed as a customer-specific modification via a ventilation hose integrated inside of the cable. For the ignition protection type nA, it must be ensured that the venting only takes place outside of the hazardous area.

On units with a rated pressure of ≤ 100 bar (≤ 1500 psi) and a $\frac{1}{2}$ " -14 NPT electrical connection, or M20x1.5 conduit, the pressure equalisation with single conductor is realised by means of a short vent line on the one hand or a bore on the other, which is located at the electrical connection conduit.

Connection must be carried out by a properly qualified specialist in accordance with the pertinent regulations pertaining to potentially explosive atmospheres (e.g. EN 60079-14). The pressure transmitters of the HDA 4000 series carry the **CE** - mark. The declaration of conformity can be found in the annex.

The requirements of the standards (see technical data) cannot be satisfied unless the pressure transmitter housing is properly grounded via the mechanical connection or the $\frac{1}{2}$ NPT Conduit. If a green-yellow wire is available, it can be used additionally for grounding, but may not be used alone as the only grounding connection. When using hose mounting the housing has to be grounded separately.

The related intrinsically safe devices (e.g. zener barriers) must also be grounded. A potential equalisation is required along the intrinsically safe electrical circuit in the N type model (insulation voltage ≤ 50 VAC).

On the HDA 4000 series, type H (insulation voltage ≤ 500 VAC), the cable length to the pressure transmitter must be max. 30 m (overvoltage protection to DIN EN 61000-6-2). If the cable length exceeds 30 m, overvoltage protection must be provided by the customer.


The General Safety Precautions (cf. section 5) must be adhered to in any event.

4 Important Mounting Instructions for Conduit Connection

4.1 Installation Instructions for Units with 1/2 " NPT Conduit


Mechanical Connection

The process installation of the transmitters may only be carried out utilizing the flats on the process connection side.



Electrical Installation

The flat at the electrical connection side only serves in order to fix the pressure transmitter during conduit installation.



4.2 Installation Instructions for units with impact protection

Installation instructions for units with M12x1 plug connector with an impact protection metal safety sleeve for the use in zones:

ATEX

II 3G Ex nA IIC T6, T5 Gc

II 1D Ex ta IIIC T80/T90 °C T₅₀₀90/ T₅₀₀100 °C Da

II 2D Ex tb III C T80/T90 °C Db

IECEx

Ex nA IIC T6, T5 Gc

Ex ta IIIC T80/T90 °C T₅₀₀90/ T₅₀₀100 °C Da


Ex tb III C T80/T90 °C Db

By adherence to safety guidelines in these protection types and applications: the usage of the impact protection metal safety sleeve is stringently required.

The impact protection metal safety sleeve must be tightened with a torque of 20 Nm.

The hex. 27 mm flats on the electrical connection side exclusively serves for fixing of the pressure transmitter during the installation of the the impact protection metal safety sleeve.

The connection of the cable with M12x1 plug may only be carried out in de-energized state and in combination with the impact protection metal safety sleeve. Also the separation of the M12x1 connector may only be carried out if the system is switched off.





5 General safety precautions

The pressure transmitter may no longer be used when the label becomes illegible.

The pressure transmitters with ignition protection type "intrinsically safe" should always be operated in combination with the suited intrinsically safe barrier.

The seals and gaskets are to be checked to see that they function properly prior to mounting and at regular intervals in keeping with the climatic conditions and the influence of the media, and to be changed as needed. Replacement seals and gaskets can be obtained from HYDAC ELECTRONIC GMBH. (Standard seal see technical data) This check is to be carried out at least every three years.

If used simultaneously in zones 0 and 1, the metal membrane of the pressure transmitter serves as a partition wall between zones 0 and 1. The thickness of this partition wall is generally ≤ 1 mm, and with a nominal pressure ranging below 100 bar, ≤ 0.2 mm. In order to ensure this partition function, the compatibility of the measuring fluids with the used materials and seals is compulsory, as well as the overload and bursting pressures must absolutely be complied with (further details, please see "Technical Data").

The "Safety-relevant Data" specified in the certificate must be adhered to.

The internal measurement membrane of the pressure transmitter is to be protected against mechanical damage.

Please ensure sufficient sealing between the zones as well.

The data pertaining to use in a hazardous location is to be heeded in any event.

Operation is only permitted when operational and process related intensive electrostatic charges are eliminated.

When used in atmospheres containing combustible dusts, the pressure transmitter must be installed in such a way that it is protected from damage and knocks.

By adherence to safety guidelines in the protection types and applications:

ATEX: II 3G Ex nA IIC T6,T5 Gc

IECEx: Ex nA IIC T6,T5 Gc

The usage of the impact protection metal safety sleeve is stringently required. The impact protection metal safety sleeve must be tightened with a torque of 20 Nm.

Operations in areas requiring category 1G equipment, are only permitted when operational and process related intensive electrostatic charges are eliminated.

6 Technical Data

6.1 HDA 4000 Standard

Input data													
Measurement ranges	bar	16	25	40	60	100	200	250	400	500	600	1050	
Overload pressures	bar	50	50	80	120	200	500	500	800	1000	1000	1400	
Burst pressure	bar	125	125	200	300	500	1250	1250	2000	3000	3000	3000	
Measurement ranges	psi	300	500	750	1500	3000	5000	6000	9000	15000			
Overload pressures	psi	725	1160	1740	2900	7250	11600	14500	14500	20300			
Burst pressure	psi	1800	2900	4350	7250	18000	29000	43500	43500	43500			
Mechanical connection (Tightening torque, recommended)	SF250CX20, autoclave (7/16-20 UNF 2B) (15 Nm for measuring range ≤ 600 bar/9000 psi) (20 Nm for measuring range 1050 bar/15000 psi) G 1/4 B DIN EN 837 (20 Nm for measuring range ≤600 bar/9000 psi) (40 Nm for measuring range 1050 bar/15000 psi)												
Parts in contact with fluid	Stainless steel	1.4435 (Ni content ≥ 13 %)											
	Measurement cell	gold-plated											
	Seal	Copper (Cu-DHP) (G 1/4 B) Zurcon ® Z22 (SAE 8)											
Output data		HDA 4400						HDA 4700					
Output signal, permitted load resistance		4...20 mA, 2 conductor, with HART Protocol $R_{Lmax.}=(UB - 12 V) / 20 \text{ mA [k}\Omega\text{]}$ With HART communication min. 250 Ω											
HART Communication		According to HART 7 specifications											
HART Common Practice Commands e.g.		Altering of measuring range limits (see table), offset adjustment within max. 3 % of the range											
Accuracy acc. to DIN 16086, terminal based	Typ. Max.	≤ ± 0.5 % FS ≤ ± 1.0 % FS						≤ ± 0.25 % FS ≤ ± 0.5 % FS					
Accuracy, B.F.S.L	Typ. Max.	≤ ± 0.25 % FS ≤ ± 0.5 % FS						≤ ± 0.15 % FS ≤ ± 0.25 % FS					
Temperature compensation Offset	Typ. Max.	≤ ± 0.015 % FS/°C [0.0085 % FS/°F] ≤ ± 0.025 % FS/°C [0.014 % FS/°F]						≤ ± 0.008 % FS/°C [0.0045 % FS/°F] ≤ ± 0.015 % FS/°C [0.0085 % FS/°F]					
Temperature compensation Span	Typ. Max.	≤ ± 0.015 % FS/°C [0.0085 % FS/°F] ≤ ± 0.025 % FS/°C [0.014 % FS/°F]						≤ ± 0.008 % FS/°C [0.0045 % FS/°F] ≤ ± 0.015 % FS/°C [0.0085 % FS/°F]					
Non-linearity acc. to DIN 16086 terminal based	Max.	≤ ± 0.3 % FS						≤ ± 0.3 % FS					
Hysteresis	Max.	≤ ± 0.4 % FS						≤ ± 0.1 % FS					
Repeatability		≤ ± 0.1 % FS						≤ ± 0.1 % FS					
Rise time		≤ 25 ms						≤ 25 ms					
Long-term drift	Typ.	≤ ± 0.3 % FS / Year						≤ ± 0.3 % FS / year					
Environmental conditions													
Compensated temperature range		-25 .. +85 °C [-13 .. +185 °F]											
Operation / ambient / fluid temperature range		T6, T80/T85 °C : Ta = -40 .. +60 °C [-40 .. +140 °F] T5, T90/T95 °C : Ta = -40 .. +70 °C [-40 .. +158 °F] T100 °C : Ta = -40 .. +80 °C [-40 .. +176 °F] T4 : -40 .. +85 °C [-40 .. +185 °F]											
Storage temperature range		-40 .. +100 °C											
CE - mark		EN 61000-6-1/ 2/ 3/ 4 ; EN 60079-0/ 11/ 15/ 26; EN 50303											
Vibration resistance acc. to DIN EN 60068-2-6 at 10 .. 500Hz		≤ 20 g ≤ 10 g in devices with electrical connection ½ NPT Conduit											
Shock resistance acc. to DIN EN 60068-2-27		≤ 100 g / 6 ms											
Protection type to ¹⁾	DIN EN 60529 ISO 20653	IP67 (connector) IP6K9K (Conduit)											

Relevant data for Ex Application		Ex ia, ic	Ex nA
Supply voltage		U _i = 12 .. 28 V	12 .. 28 V
Max. input current		I _i = 100 mA	
Maximum input power		P _i = 0.7 W	Max. power consumption ≤ 1W
Connection capacitance of the sensor		C _i = ≤ 22 nF	
Inductance of the sensor		L _i = 0 mH	
Insulation voltage ²⁾		50 V AC, with integrated overvoltage protection acc. to EN 61000-6-2 or 500 V AC	
Other data			
Residual ripple of supply voltage		According to FSK Physical Layer Specification (HCF_SPEC-054)	
Current consumption		≤ 25 mA	
Life expectancy		> 10 million load cycles 0 .. 100 % FS	
Weight		approx. 150 g (connector) approx. 300 g (Conduit)	

Note: **FS** (Full Scale) = relative to the full measuring range

B.F.S.L. = Best Fit Straight Line

Reverse polarity protection of the supply voltage, overvoltage, override and short circuit protection are provided.

¹⁾ With mounted mating connector in corresponding protection type

²⁾ See model code for "insulation voltage"

6.2 HDA 4000 with the option of temperature measurement

Additional parameters temperature measurement:

Input data									
Measurement range		Standard: -25 .. +100 °C [-13 .. +212 °F] Modification H01: -40 .. +100 °C [-40 .. +212 °F]							
Probe length		7 mm							
Mechanical connection		G 1/2 A ISO 1179-2 with probe							
Tightening torque, recommended		45 Nm							
Measuring range pressure	bar	16	40	60	100	250	400	500	
	psi	300	500	1000	3000	5000	6000		
Output data		HDA 4400				HDA 4700			
Output signal temperature		The temperature signal is available as a secondary variable via the HART protocol as a digital signal.							
Accuracy at room temperature	Typ.	± 1.0 % FS				± 0.4 % FS			
	Max.	± 2.0 % FS				± 0.8 % FS			
Temperature drift (environment)		± 0.02 % FS/°C [0.01 % FS/°F]				± 0.01 % FS/°C [0.005 % FS/°F]			
Rise time acc. to DIN EN 60751		t ₅₀ : ~ 10 s							
		t ₉₀ : ~ 15 s							

6.3 Measuring Range Limits:

By means of HART Common Practice Commands, you have the opportunity to adjust the following measuring ranges:

Measuring range limits of the primary variable (PV), pressure: for standard devices with modification H00):

Lower measuring range limit		Upper measuring range limit		Measuring span	
min	max	min	max	min	max
0 % FS	112.5 % FS	37.5 % FS	150 % FS	37.5 % FS	150 % FS

Measuring range limits of the primary variable (PV), pressure: for devices with 500 bar measuring range and modification H01):

Lower measuring range limit		Upper measuring range limit		Measuring span	
min	max	min	max	min	max
0 % FS	62.5 % FS	37.5 % FS	100 % FS	37.5 % FS	100 % FS

For devices with optional temperature measurement HDA 4000-T

Measuring range limits of the secondary variable (SV), temperature for standard devices with measuring range Temperature -25 .. +100 °C:

Lower measuring range limit		Upper measuring range limit		Measuring span	
min	max	min	max	min	max
-25 °C	75 °C	0 °C	100 °C	25 °C	125 °C

Measuring range limits of the secondary variable (SV), temperature for the device with modification H01 with Measuring range temperature -40 .. +100 °C:

Lower measuring range limit		Upper measuring range limit		Measuring span	
min	max	min	max	min	max
-40 °C	112 °C	28 °C	140 °C	28 °C	140 °C

6.4 Protocol data

HART Version: 7
 Manufacturer Code: 0x605E
 Manufacturer String: HYDAC ELECTRONIC
 Device Type Code: 0xE1BC variant with pressure as PV
 0xE2A7 variant with pressure as PV and temperature as SV

7 Model code to identify the delivered part

7.1 Standard HDA 4000

HDA 4 X X X - F21 - XXXXX - E X X - HXX (XXX)

Accuracy

4 = 1 % FS max.
7 = 0.5 % FS max.

Mechanical connection

C = SF250CX20, Autoclave (7/16-20 UNF 2B), internal thread
G = G1/4 B DIN EN 837

Electrical connection

5 = plug connector, EN175301-803, 3 pole + PE
6 = plug connector, M 12 x 1, 4 pole
9 = 1/2-14 NPT conduit, single leads

Output signal

F21 = 4 .. 20 mA, 2 conductor, with HART

Measurement ranges

4 digits for bar version
5 digits for psi version

Approval

E = ATEX and IECEx (further details, see certificates)

Insulation voltage

H = 500 V AC to housing
N = 50 V AC to housing

Protection types and application fields

ATEX	IECEx
1 = I M1 Ex ia I Ma	Ex ia I Ma
II 1 G Ex ia IIC T6, T5 Ga	Ex ia IIC T6, T5 Ga
II 1/2 G Ex ia IIC T6, T5 Ga/Gb	Ex ia IIC T6, T5 Ga/Gb
II 2 G Ex ia IIC T6, T5 Gb	Ex ia IIC T6, T5 Gb
II 1D Ex ia IIIC T85/T95 °C Da	Ex ia IIIC T85/T95 °C Da
9 = II 3G Ex nA IIC T6, T5 Gc	Ex nA IIC T6, T5 Gc
Only in conjunction with electrical connection "6" and the impact protected metal safety sleeve (see also chapter 4.2)	
C = II 3G Ex ic IIC T6, T5 Gc	Ex ic IIC T6, T5 Gc
II 3D Ex ic IIIC T80/T90 °C Dc	Ex ic IIIC T80/T90 °C Dc

Modification number

H00 = Standard

For devices with a different modification number, please read the label or the technical amendment details supplied with the device.

Cable length (for Conduit versions, not applicable for devices with connectors)

Indications in m or "(inch)

7.2 Model code HDA 4400 / HDA 4700 with additional option of temperature measurement

HDA 4 X 2 X - F21 - XXXXX - T - 007 - XXX - HXX

Mechanical connection

2 = G 1/2 A ISO 1179-2

Temperature measurement available as an option

Available via HART protocol as a digital signal

Probe length

007 = 7 mm [0.276 inch]

Modification number

H00 = Standard
H01 = Measuring range temperature -40 .. +100 °C


8 Serial number

The serial number includes the calendar week and year of manufacture of the unit, adjacent to the sequential serial number.

xyyykzzzzzz

Configuration of serial number (SN):


X	Manufacturing year	e.g.: 6 → 2016
yy	Calendar week	e.g.: 24 → KW24
k	Change control status	e.g.: -,A,B
zzzzzz	Sequential serial number	e.g.: 123456



9 PIN connection


The pin assignment for the electrical connection is shown in the chapter "Control Drawing" as well as on the type label of the pressure transmitter.

10 Dimensions




10.1 Mechanical Connection Variants

SF 250CX20, Autoclave, (7/16-20 UNF 2B), internal thread




Mechanical connection: G 1/2 A ISO 1179-2 with temperature measurement option



10.2 Electrical Connection Variants

Plug connector EN175301-803 3 pole +PE



HYDAC ELECTRONIC GMBH
Hauptstrasse 27
D-66128 Saarbruecken
Germany

Web: www.hydac.com
E-mail: electronic@hydac.com
Phone: +49 (0)6897-509-01
Fax.: +49 (0)6897 509-1726

HYDAC Service

If you have any questions concerning repair work, please do not hesitate to contact HYDAC Service:

HYDAC SERVICE GMBH
Hauptstr. 27
D-66128 Saarbruecken
Germany

Phone: +49 (0)6897-509-1936
Fax.: +49 (0)6897 509-1933

Note


The information and particulars provided in this manual apply to the operating conditions and applications described herein. For applications and/or operating conditions not described please contact the relevant technical department.

If you have any questions or suggestions or encounter any problems of a technical nature, please contact your HYDAC representative.


Subject to technical modifications.

11 Kontrollzeichnung / Control Drawing

11.1 Kontrollzeichnung Ex ia, Ex ic / Control Drawing Ex ia, Ex ic



11.2 Kontrollzeichnung Ex nA, Ex ta, tb, tc / Control Drawing Ex nA, Ex ta, tb, tc



12 Zertifikate / Certificates

12.1 ATEX



CERTIFICATE

(1) EC-Type Examination

(2) Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/EC

(3) EC-Type Examination Certificate Number: DEKRA 13ATEX0031 X Issue Number: 2

(4) Equipment: Pressure and/or Temperature and/or Flow Rate Transmitters
Model Series HDA 4...-F21-(...)-...-(...), ETS 4...-F21-(...)-...-(...)
and HFT 3...-F21-(...)-...-(...)

(5) Manufacturer: HYDAC Electronic GmbH

(6) Address: Hauptstraße 27, 66128 Saarbrücken, Germany

(7) This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., notified body number 0344 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the directive.

The examination and test results are recorded in confidential test report number NL/DEK/ExTR13.0001/xx.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0 : 2012	EN 60079-11 : 2012	EN 60079-26 : 2007
EN 60079-31 : 2009	EN 50303 : 2000	

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.

(11) This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment according to the Directive 94/9/EC. Further requirements of the directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the equipment shall include the following:



I M 1	Ex ia I Ma	or
II 1 G	Ex ia IIC T5, T6 Ga	or
II 1/2 G	Ex ia IIC T5, T6 Ga/Gb	or
II 2 G	Ex ia IIC T5, T6 Gb	or
II 1 D	Ex ta IIIC T80 °C ... T100 °C and T ₅₀₀ 90 °C ... T ₅₀₀ 110 °C Da or	
II 1 D	Ex ia IIIC T85 °C or T95 °C Da or	
II 2 D	Ex tb IIIC T80 °C ... T100 °C Db	

This certificate is issued on 28 March 2014 and, as far as applicable, shall be revised before the date of cessation of presumption of conformity of (one of) the standards mentioned above as communicated in the Official Journal of the European Union.

DEKRA Certification B.V.



M. Erdhuizen
Certification Manager

Page 1/3



© Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

(13) **SCHEDULE**

(14) to EC-Type Examination Certificate DEKRA 13ATEX0031 X

Issue No. 2

(15) **Description**

Pressure and/or Temperature and/or Flow Rate Transmitters Model Series HDA 4...-F21-(...)-...- (...), ETS 4...-F21-(...)-...- (...) and HFT 3...-F21-(...)-...- (...) are two wire transmitters used to convert a Pressure, Temperature and/or Flow Rate signal into a 4 - 20 mA output signal with digital communication (HART).

Optionally, a breathing input for pressure equalisation is available.

The electrical connections are made by a connector or via a permanently connected cable.

The enclosure provides a degree of protection of at least IP64 in accordance with EN 60529.

Ambient temperature range:

- apparatus in types of protection Ex ia IIC and Ex ia IIIC: -40 °C to +70 °C;
- apparatus in types of protection Ex ta IIIC and Ex tb IIIC: -40 °C to +80 °C.

The temperature class and the maximum surface temperature of the enclosure is depending on the maximum ambient temperature:

Max. ambient temperature	Temperature class (Ex ia/ic IIC)	Max. surface temperature "T" (Ex ta/tb/tc IIIC)	Max. surface temperature "T" (Ex ia IIIC)	Max. surface temperature "T ₅₀₀ " (Ex ta IIIC)
60 °C	T6	80 °C	85 °C	90 °C
70 °C	T5	90 °C	95 °C	100 °C
80 °C	--	100 °C		110 °C

Marking

The marking of the Transmitters includes the following codes, depending on the model:

HDA 4...-F21-(...)-.1-(...), ETS 4...-F21-(...)-.1-(...) or HFT 3...-F21-(...)-.1-(...):	I M 1 Ex ia I Ma or II 1 G Ex ia IIC T5, T6 Ga or II 1/2 G Ex ia IIC T5, T6 Ga/Gb or II 2 G Ex ia IIC T5, T6 Gb II 1 D Ex ia IIIC T85 °C or T95 °C Da
HDA 4...-F21-(...)-.2-(...), ETS 4...-F21-(...)-.2-(...) or HFT 3...-F21-(...)-.2-(...):	I M 1 Ex ia I Ma or II 2 G Ex ia IIC T5, T6 Gb
HDA 4...-F21-(...)-.3-(...), ETS 4...-F21-(...)-.3-(...) or HFT 3...-F21-(...)-.3-(...):	II 2 G Ex ia IIC T5, T6 Gb
HDA 4...-F21-(...)-.4-(...), ETS 4...-F21-(...)-.4-(...) or HFT 3...-F21-(...)-.4-(...):	II 1 G Ex ia IIC T5, T6 Ga or II 1/2 G Ex ia IIC T5, T6 Ga/Gb or II 2 G Ex ia IIC T5, T6 Gb
HDA 4...-F21-(...)-.5-(...), ETS 4...-F21-(...)-.5-(...) or HFT 3...-F21-(...)-.5-(...):	I M 1 Ex ia I Ma
HDA 4...-F21-(...)-.A-(...), ETS 4...-F21-(...)-.A-(...) or HFT 3...-F21-(...)-.A-(...):	II 1 D Ex ta IIIC T80 °C T ₅₀₀ 90 °C or T90 °C T ₅₀₀ 100 °C or T100 °C T ₅₀₀ 110 °C Da II 2 D Ex tb IIIC T80 °C or T90 °C or T100 °C Db

(13) **SCHEDULE**

(14) to EC-Type Examination Certificate DEKRA 13ATEX0031 X

Issue No. 2

Electrical dataEquipment in type of protection Intrinsic safety "i"

Supply/output circuit.(Connection + and -):

in type of protection intrinsic safety Ex ia I, Ex ia IIC and Ex ia IIIC, only for connection to a certified intrinsically safe circuit, with the following maximum values:

 $U_i = 28 \text{ V}$; $I_i = 100 \text{ mA}$; $P_i = 0,7 \text{ W}$; $C_i = 22 \text{ nF}$; $L_i = 0 \text{ mH}$.Equipment in type of protection Equipment dust ignition protection by enclosure "t"

Supply/output circuit.(Connection + and -):

 $U \leq 28 \text{ V}$; $P_{\max} = 1 \text{ W}$.

From a safety point of view, the circuits of the Pressure and/or Temperature and/or Flow Rate Transmitters type ... -F21-(...)-AN-... shall be considered to be connected to earth.

Installation instructions

The instructions provided with the equipment shall be followed in detail to assure safe operation.

(16) **Test Report**

No. NL/DEK/ExTR13.0001/xx.

(17) **Specific conditions of use**

1. Transmitters with an enclosure containing light metals, when used in a potentially explosive atmosphere requiring apparatus of equipment category 1 G or M 1, shall be installed such, that even in the event of rare incidents, an ignition source due to impact or friction between the enclosure and iron/steel is excluded.
2. For installation of the transmitter between areas where the use of category 1 apparatus is required and areas where the use of category 2 apparatus is required, the following applies:
The internal separation element shall be protected against environmental stress, which might adversely affect the separation element. The material of the separation element shall be obtained from the data supplied by the manufacturer.
3. The transmitter may alternatively be used with separately supplied certified cable entries or conduit entries that are rated for the intended application.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at (9).

(19) **Test documentation**

As listed in Test Report No. NL/DEK/ExTR13.0001/xx.



CERTIFICATE

(1) Type Examination

(2) Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/EC

(3) Type Examination Certificate Number: DEKRA 13ATEX0032 Issue Number: 2

(4) Equipment: Pressure and/or Temperature and/or Flow Rate Transmitters
Model Series HDA 4...-F21-(...)-...-(...), ETS 4...-F21-(...)-...-(...)
and HFT 3...-F21-(...)-...-(...)

(5) Manufacturer: HYDAC Electronic GmbH

(6) Address: Hauptstraße 27, 66128 Saarbrücken, Germany

(7) This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the directive.

The examination and test results are recorded in confidential test report no. NL/DEK/ExTR13.0001/xx.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0 : 2012
EN 60079-31 : 2009

EN 60079-11 : 2012

EN 60079-15 : 2010

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This Type Examination Certificate relates only to the design, examination and tests of the specified equipment and not to the manufacturing process and supply of this equipment.

(12) The marking of the equipment shall include the following:



II 3 G Ex nA IIC T4 ... T6 Gc or Ex ic IIC T4 ... T6 Gc
II 3 D Ex tc IIIC T80 °C ... T100 °C Dc or Ex ic IIIC T80 °C ... T100 °C Dc

This certificate is issued on 28 March 2014 and, as far as applicable, shall be revised before the date of cessation of presumption of conformity of (one of) the standards mentioned above as communicated in the Official Journal of the European Union.

DEKRA Certification B.V.

M. Erdhuizen
Certification Manager

Page 1/3

® Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

(13) **SCHEDULE**

(14) to Type Examination Certificate DEKRA 13ATEX0032

Issue No. 2

(15) **Description**

Pressure and/or Temperature and/or Flow Rate Transmitters Model Series HDA 4...-F21-(...)-...- (...), ETS 4...-F21-(...)-...-... and HFT 3...-F21-(...)-...-... are two wire transmitters used to convert a pressure signal into a 4 - 20 mA analogue output signal. Optionally, a breathing input for pressure equalisation is available.

Ambient temperature range -40 °C to +80 °C. (Category 3 D)

Ambient temperature range -40 °C to +85 °C. (Category 3 G)

The enclosure provides a degree of protection of at least IP64 in accordance with EN 60529.

The temperature class and the maximum surface temperature of the enclosure is depending on the maximum ambient temperature:

Max. ambient temperature	Temperature class	Max. surface temperature "T"
60 °C	T6	80 °C
70 °C	T5	90 °C
80 °C	—	100 °C
85 °C	T4	—

Marking

The marking of the Pressure Transmitter includes the following codes, depending on the model:

HDA 4...-F21-(...)-...9-(...), ETS 4...-F21-(...)-...9-(...) or HFT 3...-F21-(...)-...9-(...):	II 3 G Ex nA IIC T6, T5, T4 Gc
HDA 4...-F21-(...)-...B-(...), ETS 4...-F21-(...)-...B-(...) or HFT 3...-F21-(...)-...B-(...):	II 3 D Ex tc IIIC T80 °C/T90 °C/T100 °C Dc IP6X
HDA 4...-F21-(...)-...C-(...), ETS 4...-F21-(...)-...C-(...) or HFT 3...-F21-(...)-...C-(...):	II 3 G Ex ic IIC T6, T5, T4 Gc II 3 D Ex ic IIIC T80 °C/T90 °C/T100 °C Dc IP6X

Electrical dataApparatus in type of protection intrinsic safety "i"

Supply/output circuit (connections + and -):
in type of protection intrinsic safety Ex ic IIC, only for connection to an energy limited or intrinsically safe circuit, with the following maximum values:
 $U_i = 28 \text{ V}$; $I_i = 100 \text{ mA}$; $P_i = 0,7 \text{ W}$; $C_i = 22 \text{ nF}$; $L_i = 0 \text{ mH}$.

Apparatus in types of protection Ex nA and Ex tc

Supply/output circuit (Connection + and -):
 $U \leq 28 \text{ V}$; $P_{\text{max}} = 1 \text{ W}$.



(13) **SCHEDULE**

(14) to Type Examination Certificate DEKRA 13ATEX0032

Issue No. 2

Installation instructions

The manual provided with the equipment shall be followed in detail to assure safe operation.

(16) **Test Report**

No. NL/DEK/ExTR13.0001/xx.

(17) **Special conditions for safe use**

None.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at (9).

(19) **Test documentation**

As listed in Test Report No. NL/DEK/ExTR13.0001/xx.

12.2 IECEx

		IECEx Certificate of Conformity	
INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com			
Certificate No.:	IECEx DEK 14.0011X	issue No.:0	Certificate history:
Status:	Current		
Date of Issue:	2014-03-28	Page 1 of 3	
Applicant:	HYDAC Electronic GmbH Hauptstrasse 27 66128 Saarbrücken Germany		
Electrical Apparatus:	Pressure and/or Temperature and/or Flow Rate Transmitters Model Series HDA 4...F21- (...)-...-(...), ETS 4...F21-(...)-...-(...) and HFT 3...F21-(...)-...-(...)		
Optional accessory:			
Type of Protection:	Ex ia, Ex ic, Ex nA, Ex ta, Ex tb, Ex tc		
Marking:	Ex ia I Ma Ex ia IIC T5, T6 Ga Ex ia IIC T5, T6 Ga/Gb Ex ia IIC T5, T6 Gb Ex ia IIIC T85 °C or T95 °C Da Ex ta IIIC T80 °C T ₅₀₀ 90 °C or T90 °C T ₅₀₀ 100 °C or T100 °C T ₅₀₀ 110 °C Da Ex tb IIIC T80 °C or T90 °C or T100 °C Db Ex nA IIC T6, T5, T4 Gc Ex tc IIIC T80 °C/T90 °C/T100 °C Dc Ex ic IIC T6, T5, T4 Gc Ex ic IIIC T80 °C/T90 °C/T100 °C Dc		
Approved for issue on behalf of the IECEx Certification Body:	M. Erdhuizen		
Position:	Certification Manager		
Signature: (for printed version)			
Date:	<u>2014-03-28</u>		
1. This certificate and schedule may only be reproduced in full. 2. This certificate is not transferable and remains the property of the issuing body. 3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website .			
Certificate issued by:			
DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem The Netherlands			



IECEx Certificate of Conformity

Certificate No.: IECEx DEK 14.0011X

Date of Issue: 2014-03-28

Issue No.: 0

Page 2 of 3

Manufacturer: **HYDAC Electronic GmbH**
Hauptstrasse 27
66128 Saarbrücken
Germany

Additional Manufacturing location
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition: 6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-11 : 2011 Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-15 : 2010 Edition: 4	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
IEC 60079-26 : 2006 Edition: 2	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga
IEC 60079-31 : 2008 Edition: 1	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:
[NL/DEK/ExTR13.0001/01](#)

Quality Assessment Report:
[DE/BVS/QAR06.0017/05](#)



IECEx Certificate of Conformity

Certificate No.: IECEx DEK 14.0011X

Date of Issue: 2014-03-28

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

Pressure and/or Temperature and/or Flow Rate Transmitters Model Series HDA 4...-F21-(...)-...-(...), ETS 4...-F21-(...)-...-(...) and HFT 3...-F21-(...)-...-(...) are two wire transmitters used to convert a Pressure and/or Temperature and/or Flow Rate signal into a 4 - 20 mA output signal with digital communication (HART). Optionally, a breathing input for pressure equalisation is available.

The electrical connections are made by a connector or via a permanently connected cable.

The enclosure provides a degree of protection of at least IP64 in accordance with IEC 60529.

Ambient temperature range, depending on type of protection:

- Ex ia IIC and Ex ia IIIC: -40 °C to +70 °C;
- Ex ic IIC and Ex nA IIC: -40 °C to +85 °C;
- Ex ta IIIC, Ex tb IIIC, Ex tc IIIC and Ex ic IIIC: -40 °C to +80 °C.

For more detailed information see annex.

CONDITIONS OF CERTIFICATION: YES as shown below:

1. Transmitters with an enclosure containing light metals, when used in a potentially explosive atmosphere requiring apparatus of equipment protection level Ga or Ma, shall be installed such, that even in the event of rare incidents, an ignition source due to impact or friction between the enclosure and iron/steel is excluded.
2. For installation of the Transmitter between areas where the use of equipment protection level Ga is required and areas where the use of equipment protection level Gb is required, the following applies:
The internal separation element shall be protected against environmental stress, which might adversely affect the separation element. The material of the separation element shall be obtained from the data supplied by the manufacturer.
3. The pressure transmitter may alternatively be used with separately supplied certified cable entries or conduit entries that are rated for the intended application.

Annex: 215811500-14.0011.00-Annex to CoC.pdf



Annex 1 to Certificate of Conformity IECEx DEK 14.0011, issue 0

Description

Pressure and/or Temperature and/or Flow Rate Transmitters Model Series HDA 4...-F21-(...)-...-(...), ETS 4...-F21-(...)-...-(...) and HFT 3...-F21-(...)-...-(...) are two wire transmitters used to convert a Pressure and/or Temperature and/or Flow Rate signal into a 4 - 20 mA output signal with digital communication (HART). Optionally, a breathing input for pressure equalisation is available.

The electrical connections are made by a connector or via a permanently connected cable.

The enclosure provides a degree of protection of at least IP64 in accordance with IEC 60529.

Thermal data

Ambient temperature range, depending on type of protection:

- Ex ia IIC and Ex ia IIIC: -40 °C to +70 °C;
- Ex ic IIC and Ex nA IIC: -40 °C to +85 °C;
- Ex ta IIIC, Ex tb IIIC, Ex tc IIIC and Ex lc IIIC: -40 °C to +80 °C.

The temperature class and the maximum surface temperature of the enclosure is depending on the maximum ambient temperature, as listed in following table:

Max. ambient temperature	Temperature class (Ex nA IIC, Ex ia/ic IIC)	Max. surface temperature "T" (Ex ta/tb/tc IIIC, Ex lc IIIC)	Max. surface temperature "T" (Ex ia IIIC)	Max. surface temperature "T ₅₀₀ " (Ex ta IIIC)
60 °C	T6	80 °C	85 °C	90 °C
70 °C	T5	90 °C	95 °C	100 °C
80 °C	--	100 °C		110 °C
85 °C	T4	--	--	--

Electrical data

Equipment in type of protection Intrinsic safety "I"

Supply/output circuit.(Connection + and -):

in type of protection intrinsic safety Ex ia I, Ex ia IIC, Ex ia IIIC, Ex ic IIC and Ex lc IIIC, only for connection to a certified intrinsically safe circuit, with the following maximum values:

$U_i = 28 \text{ V}$; $I_i = 100 \text{ mA}$; $P_i = 0.7 \text{ W}$; $C_i = 22 \text{ nF}$; $L_i = 0 \text{ mH}$.

Equipment in type of protection Equipment dust ignition protection by enclosure "t" and type "n" (non-sparking nA)

Supply/output circuit.(Connection + and -):

$U \leq 28 \text{ V}$; $P_{\max} = 1 \text{ W}$.

From a safety point of view, the circuits of the transmitters type ... -F21-(...)-N.-... shall be considered to be connected to earth.



Annex 1 to Certificate of Conformity IECEx DEK 14.0011, issue 0

Marking

The marking of the Transmitters includes the following codes, depending on the model:

HDA 4...-F21-(...)-.1-(...), ETS 4...-F21-(...)-.1-(...) or HFT 3...-F21-(...)-.1-(...):	Ex ia I Ma or Ex ia IIC T5, T6 Ga or Ex ia IIC T5, T6 Ga/Gb or Ex ia IIC T5, T6 Gb Ex ia IIIC T85 °C or T95 °C Da
HDA 4...-F21-(...)-.2-(...), ETS 4...-F21-(...)-.2-(...) or HFT 3...-F21-(...)-.2-(...):	Ex ia I Ma or Ex ia IIC T5, T6 Gb
HDA 4...-F21-(...)-.3-(...), ETS 4...-F21-(...)-.3-(...) or HFT 3...-F21-(...)-.3-(...):	Ex ia IIC T5, T6 Gb
HDA 4...-F21-(...)-.4-(...), ETS 4...-F21-(...)-.4-(...) or HFT 3...-F21-(...)-.4-(...):	Ex ia IIC T5, T6 Ga or Ex ia IIC T5, T6 Ga/Gb or Ex ia IIC T5, T6 Gb Ex ia IIIC T85 °C or T95 °C Da
HDA 4...-F21-(...)-.5-(...), ETS 4...-F21-(...)-.5-(...) or HFT 3...-F21-(...)-.5-(...):	Ex ia I Ma
HDA 4...-F21-(...)-.A-(...), ETS 4...-F21-(...)-.A-(...) or HFT 3...-F21-(...)-.A-(...):	Ex ta IIIC T80 °C T ₅₀₀ 90 °C or T90 °C T ₅₀₀ 100 °C or T100 °C T ₅₀₀ 110 °C Da Ex tb IIIC T80 °C or T90 °C or T100 °C Db
HDA 4...-F21-(...)-.9-(...), ETS 4...-F21-(...)-.9-(...) or HFT 3...-F21-(...)-.9-(...):	Ex na IIC T6, T5, T4 Gc
HDA 4...-F21-(...)-.B-(...), ETS 4...-F21-(...)-.B-(...) or HFT 3...-F21-(...)-.B-(...):	Ex tc IIIC T80 °C/T90 °C/T100 °C Dc
HDA 4...-F21-(...)-.C-(...), ETS 4...-F21-(...)-.C-(...) or HFT 3...-F21-(...)-.C-(...):	Ex ic IIC T6, T5, T4 Gc Ex ic IIIC T80 °C/T90 °C/T100 °C Dc

13 Konformitätserklärungen / Declaration of conformity

HYDAC ELECTRONIC	
HYDAC ELECTRONIC GMBH, Hauptstraße 27, 66128 Saarbrücken	
HYDAC ELECTRONIC GMBH Hauptstraße 27 66128 Saarbrücken, Deutschland Telefon Zentrale 06897 509-01 Fax Einkauf 06897 509-1745 Fax Verkauf 06897 509-1735 Internet: www.hydac.com siehe dort auch: Allgemeine Geschäftsbedingungen (AGB)	
Datum	Telefon direkt
Ihr Zeichen	Telefax direkt
Ihre Nachricht	E-Mail
Unser Zeichen	
 0158	
Betreff: EU-Konformitätserklärung / EC declaration of conformity 18 / 119b / 17	
Hiermit erklären wir, dass das nachfolgend bezeichnete Produkt auf Grund seiner Konzeption und Bauart, sowie in der von uns in Verkehr gebrachten Ausführung, den grundlegenden Sicherheits- und Gesundheitsanforderungen der unten aufgeführten Normen entspricht. Bei einer nicht mit uns schriftlich abgestimmten Änderung des Produktes verliert diese Erklärung ihre Gültigkeit.	
We herewith declare that, with regard to its design and construction and to the model brought onto the market by us, the product designated below conforms with the fundamental safety and health requirements of the standards listed below. This declaration ceases to be valid if the product is modified without our written consent.	
Bezeichnung / Designation	Druckmessumformer / Pressure Transducer
Typ	HDA 4xxx-F21-xxxx-(T-xxx)-A/Exx....
EMV Richtlinie / EMC Guideline	2014/ 30 EU
Normen	DIN EN 61000-6 -1 Okt 07/ -2-März09/ - 3 /4 Sept 11
Geräte für explosionsgefährdete Bereiche / Equipment for use in potentially explosive atmospheres	2014/34 EU
Normen	EN 60079-0: 2012 ; -11: 2012 ; -26 2007 EN 60079-31: 2009 ; EN 50303 : 2000
EG Baumusterprüfbescheinigung / EC-Type Examination Certificate :	DEKRA 13 ATEX 0031X Issue: 2
DEKRA Certification B.V Utrechtseweg 310; NL 6812 AR Arnhem	
Prüfstelle / notified body :	DEKRA EXAM Nr. : no: 0158
Schutzartkennzeichen / Code for Type protection : I M1 Exia I Ma ; II 1G Ex ia IIC T5, T6 Ga; II 1/2G Ex ia IIC T5, T6 Ga/Gb; II 2G Ex ia IIC T5, T6 Gb II 1D Ex ta IIIC T80...100°C and T ₅₀₀ 90...110°C Da ; II 1D Ex ia IIIC T85°C or 95°C Da ; II 2D Ex tb IIIC T80...100°C Db	
21.07.2017	ppa J. Morsch
Datum / Date	Name / (CE-Beauftragter) (CE-authorized person)
Geschäftsführer: Matthias Dieter Dr. Franz Josef Eckle	Sitz der Gesellschaft: 66128 Saarbrücken Registergericht: Saarbrücken, HRB 6707 USt-Identnummer: DE 135 277 443 Steuernummer: 040/110/56684
Bankverbindung in Saarbrücken: Commerzbank Bank AG Nr. 316888000, BLZ 500 800 00 BIC: COMDE333 IBAN: DE77 5500 0090 0316 6888 00 Hypo Vereinsbank Nr. 353555004, BLZ 500 200 00 BIC: HYVEDE33 IBAN: DE58 5502 0090 0353 5882 84	SaarLB Nr. 5250006, BLZ 500 500 00 BIC: SALA DE 33 XXX IBAN: DE51 5005 0000 0005 2500 06 Deutsche Bank AG Nr. 035580000, BLZ 500 700 00 BIC: DEUT DE 33 XXX IBAN: DE54 5507 0000 0035 5800 00



HYDAC ELECTRONIC GMBH, Hauptstraße 27, 66128 Saarbrücken

HYDAC ELECTRONIC GMBHHauptstraße 27
66128 Saarbrücken, DeutschlandTelefon Zentrale 06897 509-01
Fax Einkauf 06897 509-1745
Fax Verkauf 06897 509-1735Internet: www.hydac.com
siehe dort auch: Allgemeine Geschäftsbedingungen (AGB)

Datum

Ihre Zeichen

Ihre Nachricht

Unser Zeichen

Betreff

Telefon direkt

Telefax direkt

E-Mail

**EU-Konformitätserklärung / EC declaration of conformity** 18 / 120a / 17

Hiermit erklären wir, dass das nachfolgend bezeichnete Produkt auf Grund seiner Konzeption und Bauart, sowie in der von uns in Verkehr gebrachten Ausführung, den grundlegenden Sicherheits- und Gesundheitsanforderungen der unten aufgeführten Normen entspricht.

Bei einer nicht mit uns schriftlich abgestimmten Änderung des Produktes verliert diese Erklärung ihre Gültigkeit.

We herewith declare that, with regard to its design and construction and to the model brought onto the market by us, the product designated below conforms with the fundamental safety and health requirements of the standards listed below.

This declaration ceases to be valid if the product is modified without our written consent.

Bezeichnung / Designation	Druckmessumformer / Pressure Transducer
Typ	HDA 4xxx-F21-xxxx-(T-xxx)-A/Exx....
EMV Richtlinie / EMC Guideline	2014/ 30 EU
Normen	DIN EN 61000-6 -1 Okt 07/ -2-März08/ - 3 /4 Sept 11
Geräte für explosionsgefährdete Bereiche / Equipment for use in potentially explosive atmospheres	2014/34 EU
Normen	EN 60079-0: 2012 ; -11: 2012 ; -15: 2010 EN 60079-31: 2009
EG Baumusterprüfbescheinigung / EU -Type Examination Certificate :	DEKRA 13 ATEX 0032 Issue: 2
DEKRA Certification B.V Utrechtseweg 310; NL 6812 AR Arnheim	
Prüfstelle / notified body :	DEKRA EXAM Nr. : no: 0158

Schutzartkennzeichen / Code for Type protection :

II 3G Ex nA IIC T4...T6 Gc or Ex ic IIC T4...T6 Gc
II 3D Ex tc IIIC T80...100°C Dc or Ex ic IIIC T80...100°C Dc

21.07.2017

Datum / Date

ppa. J. Morsch

Name /

(CE-Beauftragter) (CE-authorized person)

Geschäftsführer:
Mathias Dieter
Dr. Franz Josef EckleSitz der Gesellschaft:
66128 SaarbrückenRegistergericht:
Saarbrücken, HRB 8707

USt-Identnummer: DE 138 277 443

Steuernummer: 040/110/00654

Bankverbindung in Saarbrücken:
Commerzbank Bank AG
Nr. 316500000, BLZ 550 800 00
BIC: COMDE33HAN
IBAN: DE31 5508 0000 0316 8888 00
Hypo Vereinsbank
Nr. 353568264, BLZ 590 200 90
BIC: HYVE DE 33HAN
IBAN: DE58 5902 0090 0353 6882 64SaarLB
Nr. 5250006, BLZ 590 500 00
BIC: SALA DE 33XXX
IBAN: DE51 5905 0000 0005 2500 06
Deutsche Bank AG
Nr. 035580000, BLZ 590 700 00
BIC: DEUT DE 33HAN
IBAN: DE54 5907 0000 0005 5800 00

This image shows a full page of blank graph paper. The grid consists of small, equal-sized squares formed by thin black lines. There are no margins, text, or other markings on the page. The grid covers the entire area from edge to edge.